

# Introducing New Inspection Standards

Effective October 1, 2024, HASCO's inspection program will change from Housing Quality Standards (HQS) to National Standards for the Physical Inspection of Real Estate (NSPIRE). This is part of a nationwide effort by the US Department of Housing and Urban Development (HUD) to modernize inspections and make sure housing agencies are all looking for the same things when deciding if a unit can be rented on the voucher program.

“Landlords can expect the new model to address some of their previous concerns by increasing inspection consistency through an objective set of standards and prioritizing health, safety, and functional defects over appearance.” ([HUD Landlord Newsletter December 2023](#))

NSPIRE provides for minimum, or affirmative, habitability requirements for each area (unit inside, outside). **These areas must meet these requirements for habitability, listed in Attachment B below.** The inside, outside, and unit must be free of health and safety hazards that pose a danger to residents. Types of health and safety concerns include, but are not limited to, carbon monoxide, electrical hazards, extreme temperature, flammable materials or other fire hazards, garbage and debris, handrail hazards, infestation, lead-based paint, mold, and structural soundness [24 CFR 5.703(e)]. There are several changes to the requirements, and we encourage you to review the attachments to help you best prepare for the new inspection standards.

The Public and Federally Assisted Housing Fire Safety Act of 2022 requires all smoke alarms to have a sealed battery beginning December 29, 2024. This will also be enforced through NSPIRE.

## Examples of Specific Criteria Changes

- The interior wall (unit or inside) has a hole that is greater than 2 inches in diameter or there is an accumulation of holes that are cumulatively greater than 6 inches by 6 inches.
- There is an abrupt change in vertical elevation or horizontal separation on any walking surface along the normal path of travel, consisting of the following criteria: - An unintended ¾-inch or greater vertical difference. OR - An unintended 2-inch or greater horizontal separation that is perpendicular to the path of travel.
- Parking lot has any one pothole that is 4 inches deep and 1 square foot or greater.
- More than 3 inches of water has accumulated in a parking lot and 5% or more of the parking lot is unusable.

- ✓ **Smoke alarms:** Smoke alarms are required on each level of the home and inside each sleeping area.
- ✓ **Carbon Monoxide alarms:** Carbon monoxide alarms are required inside units and in unit inside areas such as hallways that contain a fuel-burning appliance or fireplace.
- ✓ **Cosmetic deficiencies:** Cosmetic deficiencies to a unit or its exterior are no longer considered a deficiency.



To view HUD's complete NSPIRE Checklist, visit:

[https://www.hud.gov/sites/dfiles/PIH/documents/NSPIRE\\_Fillable\\_Checklist.pdf](https://www.hud.gov/sites/dfiles/PIH/documents/NSPIRE_Fillable_Checklist.pdf)

[https://www.hud.gov/sites/dfiles/PIH/documents/HCV\\_Landlord\\_Newsletter\\_Dec2023.pdf](https://www.hud.gov/sites/dfiles/PIH/documents/HCV_Landlord_Newsletter_Dec2023.pdf)

## Correction Timeframes

When a unit does not pass inspection, landlords will be notified of what needs to be corrected. Each deficiency is identified in the NPSIRE standards as either life-threatening, severe, moderate, or low.

For units under HAP contract, deficiencies that are

- **Life-threatening** must be corrected within 24 hours after notice has been provided. Life-threatening deficiencies are listed in Attachment A below.
- **Severe** and **Moderate** must be corrected within 30 days after notice has been provided.
- **Low** result in a pass and will only be noted by the inspector for informational purposes.

## Extensions

If you need an extension to complete the corrections, please contact us. For conditions that are severe or moderate, HASCO may grant an exception to the required time frames for correcting the deficiency if HASCO determines that an extension is appropriate. For life-threatening deficiencies, HASCO may grant an extension to the 24-hour corrective action period in rare circumstances.

## Enforcement

The family and owner both have responsibilities for maintaining the unit.

### Family Responsibilities

The family is held responsible for the following deficiencies:

- Tenant-paid utilities not in service
- Failure to provide or maintain appliances owned by the family
- Damage to the unit or premises caused by a household member or guest beyond ordinary wear and tear (damages which could be assessed against the security deposit under state law or in court practice).

The family must notify the landlord when these deficiencies exist and coordinate corrections.

If the family fails to correct a discrepancy or allow the landlord to correct it within the period allowed by HASCO (and any extensions), HASCO will terminate the family's assistance, according to policies in Chapter 12 of its Administrative Plan.

*If the owner carries out a repair for which the family is responsible under the lease, the owner may bill the family for the cost of the repair.*

### Landlord Responsibilities

The landlord is responsible for all NSPIRE deficiencies not listed as a Family Responsibility above.

If the landlord fails to correct deficiencies by the time specified by HASCO, HASCO must stop housing assistance payments (also called abatement) no later than the first of the month following the specified correction period (including any approved extension) [24 CFR 985.3(f)]. No retroactive payments will be made to the owner for the period of time the rent was abated. *Owner rents are not abated as a result of deficiencies that are the family's responsibility.*

## Virtual Landlord Information Session

Join us for one of the next one-hour Virtual Landlord Information Sessions where we will discuss and answer your questions about these inspection changes.

- **Tuesday, June 11<sup>th</sup> at 3:30 pm or Wednesday, June 12<sup>th</sup> at 9:00 am.**
- To register, email [landlord@hasco.org](mailto:landlord@hasco.org) and include your name and which session you want to attend. We will send out Teams meeting links the day before each meeting.

## Attachment A: Common Life Threatening Discrepancies

NSPIRE standards describe life-threatening deficiencies that must be corrected within 24 hours.

Inspectable Item	Deficiency
Carbon Monoxide Alarm	Carbon monoxide alarm is missing, not installed, or not installed in a proper location. Carbon monoxide alarms are required inside units and in inside areas such as hallways that contain a fuel-burning appliance or fireplace, cabanas, pool rooms, or other common area amenities
	Carbon monoxide alarm is obstructed.
	Carbon monoxide alarms do not produce an audio or visual alarm when tested.
Chimney	A visually accessible chimney, flute, or firebox connected to a fireplace or wood-burning appliance is incomplete or damaged such that it may not safely contain fire and convey smoke and combustion gases to the exterior.
	Chimney exhibits signs of structural failure.
Clothes Dryer Exhaust Ventilation	The dryer transition duct is detached or missing.
	The dryer exhaust ventilation system has restricted airflow.
Egress	Obstructed means of egress.
	The sleeping room is located on the third floor or below and has an obstructed rescue opening.
	Fire escape is obstructed.
Electrical – Conductor, Outlet, and Switch	The outlet or switch is damaged.
	Exposed electrical conductor.
Exit Sign	Exit sign is damaged, missing, obstructed, or not adequately illuminated.
Fire Extinguisher	Fire extinguisher pressure gauge reads over or under-charged.
	Fire extinguisher service tag is missing, illegible, or expired.
	The fire extinguisher is damaged or missing.
Guardrail	Guardrail is missing, not installed, or not functionally adequate
Heating, Ventilation, and Air Conditioning (HVAC)	The inspection date is on or between October 1 and March 31 and the permanently installed heating source is not working or the permanently installed heating source is working and the interior temperature is below 64 degrees Fahrenheit.

Inspectable Item	Deficiency
	Combustion chamber cover or gas shutoff valve is missing from a fuel burning heating appliance.
	Fuel burning heating system or device exhaust vent is misaligned, blocked, disconnected, improperly connected, damaged, or missing.
Leak – Gas or Oil	Natural gas, propane, or oil leak.
Mold-like Substance	The presence of mold-like substances at extremely high levels is observed visually.
Smoke Alarm	Smoke alarm is not installed where required.
	The smoke alarm is obstructed.
	Smoke alarm does not produce an audio or visual alarm when tested.
Water Heater	Chimney or flue piping is blocked, misaligned, or missing.
	The gas shutoff valve is damaged, missing, or not installed.
Other	Utilities not in service, including no running hot water

## Attachment B: Affirmative Habitability Requirements

### Inside

**Inside** refers to the common areas and building systems that can be generally found within the building interior and are not inside a unit. Examples of “inside” common areas may include basements, interior or attached garages, enclosed carports, restrooms, closets, utility rooms, mechanical rooms, community rooms, daycare rooms, halls, corridors, stairs, shared kitchens, laundry rooms, offices, enclosed porches, enclosed patios, enclosed balconies, and trash collection areas. Examples of “inside” building systems include those components that provide domestic water, such as pipes, electricity, elevators, emergency power, fire protection, HVAC, and sanitary services.

Affirmative Habitability Requirements: Inside
Must include at least 1 battery-operated or hard-wired smoke detector in proper working condition on each level of the property.
Must meet or exceed the carbon monoxide detection standards set by the Secretary through <i>Federal Register</i> notification.
Any outlet installed within 6 feet of a water source must be GFCI protected.
Must have a guardrail when there is an elevated walking surface with a drop off of 30 inches or greater measured vertically.
Must have permanently mounted light fixtures in any kitchens and each bathroom.
It may not contain unvented space heaters that burn gas, oil, or kerosene.

### Outside

**Outside** refers to the building site, building exterior components, and any building systems located outside of the building or unit. Examples of “outside” components may include fencing, retaining walls, grounds, lighting, mailboxes, project signs, parking lots, detached garages or carports, driveways, play areas and equipment, refuse disposal, roads, storm drainage, non-dwelling buildings, and walkways. Components found on the exterior of the building are also considered outside areas, and examples may include doors, attached porches, attached patios, balconies, car ports, fire escapes, foundations, lighting, roofs, walls, and windows.

Affirmative Habitability Requirements: Outside
Any outlet installed within 6 feet of a water source must be GFCI-protected.
Must have a guardrail when there is an elevated walking surface with a drop off of 30 inches or greater measured vertically.

### Unit

**Unit** refers to the interior components of an individual unit. Examples of “unit” components included in the interior of a unit are the balcony, bathroom, call-for-aid (if applicable), carbon monoxide devices, ceiling, doors, electrical systems, enclosed patio, floors, HVAC (where individual units are provided), kitchen, lighting, outlets, smoke detectors, stairs, switches, walls, water heater, and windows.

## Affirmative Habitability Requirements: Unit

Must have hot and cold running water in the bathroom and kitchen, including an adequate source of safe drinking water in the bathroom and kitchen.

Must include its own bathroom or sanitary facility that is in proper operating condition and usable in privacy. It must contain a sink, a bathtub or shower, and an interior flushable toilet.

Must have at least one smoke detector, in proper working condition, in the following locations:

- On each level of the unit AND
- Inside each bedroom or sleeping area AND
- Within 21 feet of any door to a bedroom measured along a path of travel AND
- Where a smoke detector is installed outside a bedroom and is separated from an adjacent living area by a door, a smoke detector must also be installed in the living area side of the door.

If the unit is occupied by a hearing-impaired person, the smoke detectors must have an alarm system designed for hearing-impaired persons.

Must have a living room and a kitchen area with a sink, cooking appliance, refrigerator, food preparation area and food storage area.

Must have two working outlets or one working outlet and one permanent light fixture within all habitable rooms.

Must have a permanently mounted light fixture in each bathroom and in the kitchen.

Outlets within 6 feet of the water source must be GFCI-protected.

Must have permanently installed heating source.

No units may contain unvented space heaters that burn gas, oil, or kerosene.

Must have a guard rail when there is an elevated walking surface with a drop-off of 30 inches or greater measured vertically.

Must have at least one bedroom or living/sleeping room for each two persons.

# NSPIRE HCV/PBV INSPECTION CHECKLIST

PHA:	Address of Unit:		
Family Identifier:	Owner:		
Any children under 6 reside or expected to reside in the unit? (Y/N):	Owner Contact Information:		
Inspector:	Housing Type:		
Date of Inspection:	Year Constructed:		
Type of Inspection:	Number of Bedrooms:		

<b>Summary Decision on Unit (Pass/Fail):</b>			
			<b>Correction Timeframe (P/F)</b>
	LT		<b>Life-Threatening - 24 Hours (Fail)</b>
	S		Severe - 30 Days (Fail)
	M		Moderate - 30 Days (Fail)
	L		Low - N/A (Pass)

\*Affirmative Habitability Requirement per 24 CFR 5.703(d) and NSPIRE Final Rule

**Mark all that apply:**

Area	Deficiency Description	Unit	Inside	Outside	Inspector Comments
Address and Signage	Address, signage, or building identification codes are broken, illegible, or not visible.			M <input type="checkbox"/>	
	Only 1 bathtub or shower is present and it is inoperable or does not drain.	S <input type="checkbox"/>	L <input type="checkbox"/>		
	A bathtub or shower is inoperable or does not drain and at least 1 bathtub or shower is present elsewhere that is operational.	M <input type="checkbox"/>	L <input type="checkbox"/>		
Bathtub and Shower	Bathtub component or shower component is damaged, inoperable, or missing such that it may limit the resident's ability to maintain personal hygiene.	M <input type="checkbox"/>	L <input type="checkbox"/>		
	Bathtub component or shower component is damaged, inoperable, or missing and it does not limit the resident's ability to maintain personal hygiene.	L <input type="checkbox"/>			
	Bathtub or shower cannot be used in private.*	*M <input type="checkbox"/>	M <input type="checkbox"/>		
	Food storage space is not present.*	*M <input type="checkbox"/>			
Cabinet and Storage	Storage component is damaged, inoperable, or missing.	M <input type="checkbox"/>	L <input type="checkbox"/>		
	<b>System is blocked, or pull cord is higher than 6 inches off the floor.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>		
	<b>System does not function properly.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>		
	<b>Carbon monoxide alarm is missing, not installed, or not installed in a proper location.*</b>	LT <input type="checkbox"/>			
Carbon Monoxide	<b>Carbon monoxide alarm is obstructed.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>		
	<b>Carbon monoxide alarm does not produce an audio or visual alarm when tested.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>		
	Ceiling has an unstable surface.	M <input type="checkbox"/>	M <input type="checkbox"/>		
Ceiling	Ceiling has a hole.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Ceiling component(s) is not functionally adequate.	S <input type="checkbox"/>	S <input type="checkbox"/>		
	<b>A visually accessible chimney, flue, or firebox connected to a fireplace or wood-burning appliance is incomplete or damaged such that it may not safely contain fire and convey smoke and combustion gases to the exterior.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	
Chimney	<b>Chimney exhibits signs of structural failure.</b>			LT <input type="checkbox"/>	

Area	Deficiency Description	Unit	Inside	Outside	Inspector Comments
Clothes Dryer Exhaust Ventilation	Electric dryer transition duct is detached or missing.	LT <input type="checkbox"/>	LT <input type="checkbox"/>		
	Gas dryer transition duct is detached or missing.	LT <input type="checkbox"/>	LT <input type="checkbox"/>		
	Electric dryer exhaust ventilation system has restricted airflow.	LT <input type="checkbox"/>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	
	Dryer transition duct is constructed of unsuitable material.	LT <input type="checkbox"/>	LT <input type="checkbox"/>		
	Gas dryer exhaust ventilation system has restricted airflow.	LT <input type="checkbox"/>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	
	Exterior dryer vent cover, cap, or a component thereof is missing.			L <input type="checkbox"/>	
	Cooking range, cooktop, or oven does not ignite or produce heat.	S <input type="checkbox"/>	L <input type="checkbox"/>		
	Cooking range, cooktop, or oven component is damaged or missing such that the device is unsafe for use.	M <input type="checkbox"/>	M <input type="checkbox"/>		
Cooking Appliance	Primary cooking appliance is missing.*	*M <input type="checkbox"/>			
	A microwave is the primary cooking appliance and it is damaged.	S <input type="checkbox"/>			
	A burner does not produce heat, but at least 1 other burner is present on the cooking range or cooktop and does produce heat.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Entry door will not open.	M <input type="checkbox"/>	M <input type="checkbox"/>		
Door - Entry	Entry door will not close.	S <input type="checkbox"/>	M <input type="checkbox"/>		
	Entry door self-closing mechanism is damaged, inoperable, or missing.	S <input type="checkbox"/>	M <input type="checkbox"/>		
	Hole, split, or crack that penetrates completely through entry door.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Entry door is missing.	LT <input type="checkbox"/>	S <input type="checkbox"/>		
	Entry door surface is delaminated or separated.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Entry door frame, threshold, or trim is damaged or missing.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Entry door seal, gasket, or stripping is damaged, inoperable, or missing.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Entry door component is damaged, inoperable, or missing and it does not limit the door's ability to provide privacy or protection from weather or infestation.	L <input type="checkbox"/>	L <input type="checkbox"/>		
	Entry door cannot be secured.	S <input type="checkbox"/>	M <input type="checkbox"/>		
	Fire labeled door does not open.	S <input type="checkbox"/>	S <input type="checkbox"/>		
Door - Fire	Fire labeled door does not close and latch or the self-closing hardware is damaged or missing such that the door does not self-close and latch.	S <input type="checkbox"/>	S <input type="checkbox"/>		
	Fire labeled door assembly has a hole of any size or is damaged such that its integrity may be compromised.	S <input type="checkbox"/>	S <input type="checkbox"/>		
	Fire labeled door seal or gasket is damaged or missing.	S <input type="checkbox"/>	S <input type="checkbox"/>		
	An object is present that may prevent the fire labeled door from closing and latching or self-closing and latching.	S <input type="checkbox"/>	S <input type="checkbox"/>		
Door - General	Fire labeled door cannot be secured.	S <input type="checkbox"/>	M <input type="checkbox"/>		
	Fire labeled door is missing.	LT <input type="checkbox"/>	LT <input type="checkbox"/>		
	A passage door does not open.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	A passage door component is damaged, inoperable, or missing and the door is not functionally adequate.	L <input type="checkbox"/>	L <input type="checkbox"/>		
	A door that is not intended to permit access between rooms has a damaged, inoperable, or missing	L <input type="checkbox"/>			
	An exterior door component is damaged, inoperable, or missing.			M <input type="checkbox"/>	

Area	Deficiency Description	Unit	Inside	Outside	Inspector Comments
Drain	Drain is fully blocked.	M <input type="checkbox"/>	M <input type="checkbox"/>	M <input type="checkbox"/>	
Egress	<b>Obstructed means of egress.</b> <b>Sleeping room is located on the 3rd floor or below and has an obstructed rescue opening.</b> <b>Fire escape access is obstructed.</b> <b>Outlet or switch is damaged.</b>	LT <input type="checkbox"/> LT <input type="checkbox"/> LT <input type="checkbox"/>	LT <input type="checkbox"/> LT <input type="checkbox"/> LT <input type="checkbox"/>	LT <input type="checkbox"/> LT <input type="checkbox"/> LT <input type="checkbox"/>	
Electrical - Conductor, Outlet, and Switch	Testing indicates a three-pronged outlet is not properly wired or grounded. Outlet does not have visible damage and testing indicates it is not energized.	S <input type="checkbox"/> S <input type="checkbox"/>	S <input type="checkbox"/> S <input type="checkbox"/>	S <input type="checkbox"/> S <input type="checkbox"/>	
Electrical - GFCI/AFCI	<b>Exposed electrical conductor.</b> <b>Water is currently in contact with an electrical conductor.</b> GFCI outlet or GFCI breaker is not visibly damaged and the test or reset button is inoperable. AFCI outlet or AFCI breaker is not visibly damaged and the test or reset button is inoperable. An unprotected outlet is present within six feet of a water source.*	LT <input type="checkbox"/> LT <input type="checkbox"/> S <input type="checkbox"/> S <input type="checkbox"/> *S <input type="checkbox"/>	LT <input type="checkbox"/> LT <input type="checkbox"/> S <input type="checkbox"/> S <input type="checkbox"/> *S <input type="checkbox"/>	LT <input type="checkbox"/> LT <input type="checkbox"/> S <input type="checkbox"/> S <input type="checkbox"/> *S <input type="checkbox"/>	
Electrical - Service Panel	Electrical service panel is not readily accessible. <b>The overcurrent protection device is damaged.</b>	M <input type="checkbox"/> LT <input type="checkbox"/>	M <input type="checkbox"/> LT <input type="checkbox"/>	M <input type="checkbox"/> LT <input type="checkbox"/>	
Elevator	The overcurrent protection device is contaminated. Elevator is inoperable. Elevator door does not fully open and close. Elevator cab is not level with the floor. Safety edge device has malfunctioned or is inoperable.	S <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/>	S <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/>	S <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/> M <input type="checkbox"/>	
Exit Sign	<b>Exit sign is damaged, missing, obstructed, or not adequately illuminated.</b> Fence component is missing.	LT <input type="checkbox"/> M <input type="checkbox"/>	LT <input type="checkbox"/> M <input type="checkbox"/>	LT <input type="checkbox"/> M <input type="checkbox"/>	
Fence and Gate	Gate does not open, close, latch, or lock. Fence demonstrates signs of collapse.	M <input type="checkbox"/> M <input type="checkbox"/>	M <input type="checkbox"/> M <input type="checkbox"/>	M <input type="checkbox"/> M <input type="checkbox"/>	
Fire Escape	<b>Fire escape component is damaged or missing.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	
Fire Extinguisher	<b>Fire extinguisher pressure gauge reads over or under-charged.</b> <b>Fire extinguisher service tag is missing, illegible, or expired.</b> <b>Fire extinguisher is damaged or missing.</b>	LT <input type="checkbox"/> LT <input type="checkbox"/> LT <input type="checkbox"/>	LT <input type="checkbox"/> LT <input type="checkbox"/> LT <input type="checkbox"/>	LT <input type="checkbox"/> LT <input type="checkbox"/> LT <input type="checkbox"/>	
Flammable and Combustible Item	<b>Flammable or combustible item is on or within 3 feet of an appliance that provides heat for thermal comfort or a fuel-burning water heater.</b> <b>OR</b> <b>Improperly stored chemicals.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	
Floor	Floor substrate is exposed. Floor component(s) is not functionally adequate.	M <input type="checkbox"/> M <input type="checkbox"/>	M <input type="checkbox"/> M <input type="checkbox"/>	M <input type="checkbox"/> M <input type="checkbox"/>	
Food Preparation	Food preparation area is not present.* Food preparation area is damaged or is not functionally adequate.	*M <input type="checkbox"/> M <input type="checkbox"/>	*M <input type="checkbox"/> M <input type="checkbox"/>	*M <input type="checkbox"/> M <input type="checkbox"/>	

Area	Deficiency Description	Unit	Inside	Outside	Inspector Comments
Foundation	Foundation is cracked.	M	M	M	
	Foundation has exposed rebar or foundation is spalling, flaking, or chipping.	M	M	M	
	Foundation is infiltrated by water.	M	M		
	Foundation support post, column, beam, or girder is damaged.	M	M	M	
	Foundation vent cover is missing or damaged.			M	
Garage Door	Garage door has a hole.	M	M	M	
	Garage door does not open, close, or remain open or closed.	M	M	M	
Guardrail	Grab bar is not secure.	M	M		
	<b>Guardrail is missing or not installed.*</b>	*LT	*LT	*LT	
Handrail	<b>Guardrail is not functionally adequate.</b>	LT	LT	LT	
	Handrail is missing.	M	M	M	
	Handrail is not secure.	M	M	M	
	Handrail is not functionally adequate.	M	M	M	
	Handrail is not installed where required.		L	L	
	<b>The inspection date is on or between October 1 and March 31 and the permanently installed heating source is not working or the permanently installed heating source is working and the interior temperature is below 64 degrees Fahrenheit.*</b>	*LT			
HVAC	The inspection date is on or between October 1 and March 31 and the permanently installed heating source is working and the interior temperature is 64 to 67.9 degrees Fahrenheit.*	*S			
	Air conditioning system or device is not operational.	M	L		
	<b>Unvented space heater that burns gas, oil, or kerosene is present.*</b>	*LT	*LT		
	<b>Combustion chamber cover or gas shutoff valve is missing from a fuel burning heating appliance.</b>	LT	LT		
	Heating system or device safety shield is damaged or missing.	S	S		
	The inspection date is on or between April 1 and September 30 and a permanently installed heating source is damaged, inoperable, missing, or not installed.*	*M	*M		
	<b>Fuel burning heating system or device exhaust vent is misaligned, blocked, disconnected, improperly connected, damaged, or missing.</b>	LT	LT	LT	
	The inspection date is on or between October 1 and March 31 and the permanently installed heating source is inoperable.		M		
	Evidence of cockroaches.	M	M		
	Extensive cockroach infestation.	S	M		
Infestation	Evidence of bedbugs.	M	M		
	Extensive bedbug infestation.	S	M		
	Evidence of mice.	M	M		
	Extensive mouse infestation.	S	M		
	Evidence of rats.	M	M	M	
	Extensive rat infestation.	S	S		
	Evidence of other pests.	M	M		

Area	Deficiency Description	Unit	Inside	Outside	Inspector Comments
Leak - Gas/Oil	<b>Natural gas, propane, or oil leak.</b>	LT	LT	LT	
	Blocked sewage system.	S	S	S	
Leak - Sewage	Leak in sewage system.	S	S	S	
	Cap to the cleanout or pump cover is detached or missing.	M	M	M	
	Cleanout cap or riser is damaged.	M	M	M	
Leak - Water	Environmental water intrusion.	M	M		
	Plumbing leak.	M	M	L	
	Fluid is leaking from the sprinkler assembly.	M	M	L	
Lighting - Auxiliary	Auxiliary lighting is damaged, missing, or fails to illuminate when tested.		S	S	
Lighting - Exterior	A permanently installed light fixture is damaged, inoperable, missing, or not secure.			M	
	A permanently installed light fixture is inoperable.	M	M		
Lighting - Interior	A permanently installed light fixture is not secure.	M	M		
	At least one (1) permanently installed light fixture is not present in the kitchen and bathroom.*	*M	*M		
Litter	Litter is accumulated in an undesignated area.		M	L	
Minimum Electrical and Lighting	At least two (2) working outlets are not present within each habitable room. OR At least one (1) working outlet and one (1) permanently installed light fixture is not present within each habitable room.*	*M			
	Presence of mold-like substance at moderate levels is observed visually.	M	L		
	Presence of mold-like substance at high levels is observed visually.	S	M		
Mold-Like Substance	<b>Presence of mold-like substance at extremely high levels is observed visually.</b>	LT	S		
	Elevated moisture level.	M	L		
Parking Lot	Parking lot has any one pothole that is 4 inches deep and 1 square foot or greater.			M	
	Parking lot has ponding.			M	
	Paint in a Unit or Inside the target property is deteriorated – below the level required for lead-safe work practices by a lead-certified firm or for passing clearance.	M	M		
Potential Lead-Based Paint Hazards - Visual Assessment	Paint in a Unit or Inside the target property is deteriorated – above the level required for lead-safe work practices by a lead-certified firm and passing clearance.	S	S		
	Paint Outside on a target property is deteriorated – below the level required for lead-safe work practices by a lead-certified firm or for passing clearance.			M	
	Paint Outside on a target property is deteriorated – above the level required for lead-safe work practices by a lead-certified firm and passing clearance.			S	
Private Roads and Driveways	Road or driveway access to the property is blocked or impassable for vehicles.			S	
	Road or driveway has any one pothole that is 4 inches deep and 1 square foot or greater.			M	
Refrigerator	Refrigerator is inoperable such that it may be unable to safely and adequately store food.	M	M		
	Refrigerator component is damaged such that it impacts functionality.	M	M		
	Refrigerator is missing.*	*M			

Area	Deficiency Description	Unit	Inside	Outside	Inspector Comments
Retaining Wall	Retaining wall is leaning away from the fill side.			M	
	Retaining wall is partially or completely collapsed.			M	
Roof Assembly	Restricted flow of water from a roof drain, gutter, or downspout.			M	
	Gutter component is damaged, missing, or unfixed.			M	
	Roof surface has standing water.			M	
	Substrate is exposed.			M	
	Roof assembly has a hole.			M	
	Roof assembly is damaged.			M	
Sharp Edges	A sharp edge that can result in a cut or puncture hazard is present.	S	S	S	
Sidewalk, Walkway, Ramp	Sidewalk, walkway, or ramp is blocked or impassable.			M	
	Sidewalk, walkway, or ramp is not functionally adequate.			M	
	Sink or sink component is damaged or missing and the sink is not functionally adequate.	M	L		
Sink	Water is directed outside of the basin.	L	L		
	Sink is not draining.	M	M		
	Sink is improperly installed, pulling away from the wall, leaning, or there are gaps between the sink and wall.	M	M		
	Sink component is damaged or missing and the sink is functionally adequate.	L	L		
	Cannot activate or deactivate hot and cold water.*	*M	M		
	Sink is missing or not installed within the primary kitchen.*	*M			
Site Drainage	Water runoff is unable to flow through the site drainage system.			L	
	Erosion is present.			L	
	Grate is not secure or does not cover the site drainage system's collection point.			M	
Smoke Alarm	<b>Smoke alarm is not installed where required.*</b>	*LT	*LT		
	<b>Smoke alarm is obstructed.</b>	LT	LT		
	<b>Smoke alarm does not produce an audio or visual alarm when tested.</b>	LT	LT		
Sprinkler Assembly	<b>Sprinkler head assembly is encased or obstructed by an item or object that is within 18 inches of the sprinkler head.</b>	LT	LT	LT	
	<b>Sprinkler assembly component is damaged, inoperable, or missing and it is detrimental to performance.</b>	LT	LT		
	<b>Sprinkler assembly has evidence of corrosion.</b>	LT	LT	LT	
Stairs	Tread is missing or damaged.	M	M	M	
	Stringer is damaged.	M	M	M	
Steps and Stairs	Step or stair is not functionally adequate.			M	
Structure	<b>Structural system exhibits signs of serious failure.</b>	LT	LT	LT	

Area	Deficiency Description	Unit	Inside	Outside	Inspector Comments
	<b>Only 1 toilet was installed, and it is missing.</b>	LT <input type="checkbox"/>	M <input type="checkbox"/>		
	A toilet is missing and at least 1 toilet is installed elsewhere that is operational.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Only 1 toilet was installed, and it is damaged or inoperable.	S <input type="checkbox"/>	M <input type="checkbox"/>		
	A toilet is damaged or inoperable and at least 1 toilet is installed elsewhere that is operational.	M <input type="checkbox"/>	M <input type="checkbox"/>		
Toilet	Toilet component is damaged, inoperable, or missing such that it may limit the resident's ability to safely discharge human waste.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Toilet is not secured at the base.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Toilet component is damaged, inoperable, or missing and it does not limit the resident's ability to discharge human waste.	L <input type="checkbox"/>	L <input type="checkbox"/>		
	Toilet cannot be used in private. *	*M <input type="checkbox"/>	M <input type="checkbox"/>		
Trash Chute	Chute door does not open or self-close and latch.		M <input type="checkbox"/>		
	Chute is clogged.		M <input type="checkbox"/>		
Trip Hazard	Trip hazard on walking surface.	M <input type="checkbox"/>	M <input type="checkbox"/>	M <input type="checkbox"/>	
	Exhaust system does not respond to the control switch.	M <input type="checkbox"/>	M <input type="checkbox"/>		
Ventilation	Exhaust system has restricted airflow.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Exhaust system component is damaged or missing.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Bathroom does not have proper ventilation or dehumidification.	M <input type="checkbox"/>	M <input type="checkbox"/>		
Wall - Exterior	Exterior wall covering has missing sections of at least 1 square foot per wall.			M <input type="checkbox"/>	
	Exterior wall has peeling paint of 10 square feet or more.			M <input type="checkbox"/>	
	Exterior wall component(s) is not functionally adequate.			M <input type="checkbox"/>	
Wall - Interior	Interior wall has a loose or detached surface covering.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Interior wall component(s) is not functionally adequate.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Interior wall has a hole that is greater than 2 inches in diameter or there is an accumulation of holes that are cumulatively greater than 6 inches by 6 inches.	M <input type="checkbox"/>	M <input type="checkbox"/>		
	Temperature pressure relief (TPR) valve has an active leak or is obstructed or relief valve discharge piping is damaged, capped, has an upward slope, or is constructed of unsuitable material.	S <input type="checkbox"/>	S <input type="checkbox"/>	S <input type="checkbox"/>	
	No hot water.	S <input type="checkbox"/>	L <input type="checkbox"/>		
Water Heater	The relief valve discharge piping is missing or terminates greater than 6 inches or less than 2 inches from waste receptor flood-level.	M <input type="checkbox"/>	M <input type="checkbox"/>	M <input type="checkbox"/>	
	<b>Chimney or flue piping is blocked, misaligned, or missing.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	
	<b>Gas shutoff valve is damaged, missing, or not installed.</b>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	LT <input type="checkbox"/>	
	Window will not open or stay open.	M <input type="checkbox"/>	L <input type="checkbox"/>		
Window	Window cannot be secured.	M <input type="checkbox"/>	L <input type="checkbox"/>		
	Window will not close.	S <input type="checkbox"/>	M <input type="checkbox"/>		
	Window component is damaged or missing and the window is not functionally adequate.	M <input type="checkbox"/>	M <input type="checkbox"/>		

Note: This checklist is not a standards form and is not required for use. The form or its data should not be submitted to HUD, and will not be collected or maintained by HUD. No PI data should be submitted, nor will it be collected. The housing authority or owner is responsible for compliance with the HUD NSPIRE Standards per the NSPIRE Final Rule (88 FR 30442) and accompanying Federal Register Notices (88 FR 40832, 88 FR 66882).